

Dt. 20.07.2023.

Salem. 636 001.

NO OBJECTION CERTIFICATE

Sub:- TamilNadu Fire and Rescue Services – Office of the Fire and Rescue Station, Salem – Issue to No objection Certificate for School Recognition – Regarding.

Ref:-

1. Government Order No. 117, School Education (Q1) Department, Dated. 07.09.2004
2. Government Order No. 122, School Education (2) Department, Dated. 14.09.2004
3. Government Order No. 123, School Education (2) Department, Dated. 14.09.2004
4. Application dated 18.07.2023 from the principal of CLUNY VIDYA NIKETHAN SCHOOL, Salem-636015.

With reference to the above Government Orders and an Application by CLUNY VIDYA NIKETHAN SCHOOL, survey NO: 55 / 3B2A, 55 / 3B2B, 56 / 10B, 56 / 2B, 3B, 4B, 5B, 56 / 8, 9, 76 / 1A1A, 76 / 5A1A1, Door No:2 / 636, Attur Bye-Pass Road, Erumapalayam village, Salem District, salem-636015 was inspected on 20.07.2023 by Thiru. P.Sivakumar, Assistant Distict Officer, Salem Fire and Rescue Station in the view of our Fire and Rescue Services Department there is NO OBJECTION for granting Recognition to the above said School.

This certificate is valid up to 19.07.2024.

Conditions:

1. This Certificate is valid for One Year from the date of issue.
2. Fire Protection devices shall be placed in (Generator room, Class room, Laboratory and Computer room) the wall or easy to handle as per provisions of National Building code 2015 and Indian Standards.
3. Water Tanks should always be kept in full.
4. Mock drill should be conducted periodically.
5. Emergency exit signs should be in red colour that even glows in the dark.
6. First Aid kit should be kept and used properly.
7. Do not accumulate waste materials in the School premises.
8. Cooking room should be separate from the School building and LPG gas cylinders should be used safely without leakage.



[Signature]
Assistant District Officer
Fire and Rescue Services
Salem - 636 001
Salem District

To:-

The Principal,
CLUNY VIDYA NIKETHAN SCHOOL,
Door No:2 / 636, Attur Bye-Pass Road, Erumapalayam village,
Salem Taluk, Salem District, Salem-636 015.

Copy to:-

1. The Joint Director, Fire and Rescue Services, Salem Region, Salem-16
2. District Officer, Salem District.

Sr. Thecla Joseph
CORRESPONDENT
CLUNY VIDYA NIKETHAN
ERUMAPALAYAM, SALEM-636 015.

[Signature]
PRINCIPAL
CLUNY VIDYA NIKETHAN
ERUMAPALAYAM, SALEM-636 015.