



GOVERNMENT OF TAMILNADU
DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
SANITARY CERTIFICATE
YEAR 2023-2024
APPENDIX-3

(Chapter III Rule: 24)

Tamil Nadu Educational Rules

L.No.6111 /A1/2023, dt: 24.07.2023

Office of the Deputy Director of
Health Services, Salem.

I hereby declare that I have inspected **M/s. CLUNY VIDYA NIKETHAN SCHOOL, D.NO:2/636, S.NO:55/3B2A, 55/3B2B, 56/10B, 56/2B, 3B, 4B, 5B, 56/8, 9, 76/1A1A, 76/5A1A1, ATTUR BYE-PASS ROAD, ERUMAPALAYAM VILLAGE, SALEM TALUK, SALEM DT-636 015.** Building and premises on the day of **24.07.2023** and certify that

- : The accommodation provided for each of the several classes is sufficient for the maximum number of students studying therein and is properly ventilated and lighted;
- : The building is maintained in substantial repair;
- : The building is neat and clean;
- : The toilet arrangements are adequate and satisfactory;
- : The supply of drinking water is wholesome and
- : That in all other necessary aspects the sanitation is satisfactory;
- : That there is no sources of mosquito breeding in the campus if found later
- : This certificate will be automatically stands cancelled.
- : The certificate is issued with the condition enclosed.

This certificate is valid for the **one year-2023-2024** only.

Counter Signed:
TECHNICAL PERSONAL ASSISTANT
Office of the DDHS,
SALEM-636 001.



Signature: *V.V. b...*
Designation: **BLOCK HEALTH SUPERVISOR**
GOVT. PRIMARY HEALTH CENTRE
KANNANKURUCHI
SALEM.

hij...
Deputy Director
Health Services, Salem.
Ad

CERTIFICATE IS ISSUED SUBJECT TO THE FOLLOWING CONDITIONS:

- 1) The Garbage generated within the premises should be collected and disposed off properly by appointing required sanitary staff.
- 2) On any account, the Garbage should not be burnt.
- 3) The employees should be educated to prevent the usage of plastics in the premises and no one should bring plastic carry bags, use and throw Tumblers to the premises.
- 4) To ensure that no mosquitogenic environment in the campus under section 83 of TNPH Act, 1939.
- 5) N.O.C. (or) License for Building to be obtained under TNPH Act 1939 and Buildings Act 1965.
- 6) Fire Precautionary measures, and First Aid box, should be provided in the campus.
- 7) Sign Board regarding 'No Smoking Zone', 'Here Smoking and Spitting is an offence' should be exhibited in front of the premise.
- 8) This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of sanitation, improper maintenance of the building as well as toilets in the premises.
- 9) That if any of all above conditions are not satisfied the Certificate given will be automatically cancelled.
- 10) This certificate should be **renewed every year.**

Sr. Thecla Joseph
CORRESPONDENT
CLUNY VIDYA NIKETHAN
ERUMAPALAYAM, SALEM-636 015.


PRINCIPAL
CLUNY VIDYA NIKETHAN
ERUMAPALAYAM, SALEM-636 015.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY

TWAD Board, No.397,ANBU NAGAR GORIMEDU,SALEM – 636 008.

Phone: 0427-2405687

E-mail: twadboardsalemlab@gmail.com



TC - 10393

TEST REPORT

Sample Receipt No/Date :	59042-59043/Dt.29.11.2023
Invoice Details :	6956/Dt.29.11.2023
Customer Name and Address :	Cluny Vidya Nikethan (Senior Secondary School),2/636, Attur Bypass Road,Erumapalayam,Salem-636015.
Test Commenced on :	29.11.2023
Test Completed on :	30.11.2023
Test Report Date :	01.12.2023
SAMPLE DETAILS FURNISHED BY CUSTOMER	
Source :	RO Water.
Location :	RO @ Cluny Vidya Nikethan,2/636,Attur Bypass road, Salem .
Sample drawn by/Date :	Customer/Dt.29.11.2023
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
The test result of sample received is as follows.	

S.No	I. CHEMICAL EXAMINATION	Method of Testing	Unit	Sample No. 59042 Result	Specification as per IS 10500 : 2012
					Permissible Limit
1	pH at 25°C	IS 3025 Part 11-1983	-	6.55	6.5-8.5
2	Total Alkalinity as CaCO ₃	IS 3025-Part 23-1986	mg/L	40	600
3	Total Hardness as CaCO ₃	IS 3025 Part 21-2009	mg/L	36	600
4	Chloride as Cl	IS 3025-Part 32-1988	mg/L	8	1000
5	Sulphate as SO ₄	IS 3025-Part 24-1986	mg/L	4	400
6	Nitrate as NO ₃	APHA 23rd Edition 2017- 4500 -NO2 B	mg/L	0	45
7	Fluoride as F	APHA 23rd Edition 2017 - 4500- F-D	mg/L	0.2	1.5

.....End of the report.....

Romya
01/12/2023
Authorised Signatory,
TWAD Board, R.W.S,
Salem.

Note:

1. The test results relate only to the tested sample.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.




TEST REPORT

Sample Receipt No/Date :	59042-59043/Dt.29.11.2023
Invoice Details :	6956/Dt.29.11.2023
Customer Name and Address :	Cluny Vidya Nikethan (Senior Secondary School),2/636, Attur Bypass Road,Erumapalayam,Salem-636015.
Test Commenced on :	29.11.2023
Test Completed on :	30.11.2023
Test Report Date :	01.12.2023
SAMPLE DETAILS FURNISHED BY CUSTOMER	
Source :	RO Water.
Location :	RO @ Cluny Vidya Nikethan,2/636,Attur Bypass road, Salem .
Sample drawn by/Date :	Customer/Dt.29.11.2023
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
Appearance, Colour, Odour :	Clear/Colourless/Agreeable
The test result of sample received is as follows.	

S.No	I. Physical Examination	Method of Testing	Unit	Sample No. 59042 Result	Specification as per IS 10500 : 2012
					Permissible Limit
8	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	5
9	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	84	2000
10	Electrical Conductivity	APHA 23rd Edition 2017 - 2510 B	µS/cm	120	-
II. Chemical Examination					
11	Ph. Alkalinity as CaCO ₃	IS 3025-Part 23-1983	mg/L	0	-
12	Calcium as Ca	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	8	200
13	Magnesium as Mg	APHA 23rd Edition 2017- 3500 Mg B	mg/L	4	100
14	Sodium as Na	APHA 23rd Edition 2017 - 3500 Na B	mg/L	-	-
15	Potassium as K	APHA 23rd Edition 2017 - 3500 K B	mg/L	-	-
16	Iron as Fe	APHA 23rd Edition 2017- 3500 Fe B	mg/L	0.00	1
17	Manganese as Mn	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0.00	0.3
18	Free Ammonia as NH ₃	APHA 17th Edition-1989- 4500 NH ₃ C	mg/L	0.00	0.5
19	Nitrite as NO ₂	APHA 23rd Edition 2017- 4500-NO ₃ B	mg/L	0.00	-
20	Phosphate as PO ₄	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.00	-
21	Free residual chlorine	BIS 10500:2012	mg/L	0.00	-
III. Bacteriological Examination				59043	
22	Faecal Coliform per 100 ml	IS/APHA	CFU	0	0

.....End of the report.....


01/12/2023
Authorised Signatory,
TWAD Board,R.W.S,
Salem.

Note:

1. The test results relate only to the tested sample.