



GOVERNMENT OF TAMILNADU
DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
SANITARY CERTIFICATE

YEAR 2025-2026

APPENDIX-3 - (Chapter III Rule:24)

Tamil Nadu Educational Rules

L.No.5517/E3/2025, dt: 07.07.2025

Office of the District
Health Officer, Salem.

I hereby declare that I have inspected **M/s. CLUNY VIDYA NIKETHAN SCHOOL, D.NO. 2/636, S.NO. 55/3B2A, 55/3B2B, 56/10B, 56/2B, 3B, 4B, 5B, 9, 76/1A1A, 76/5A1A1, ATTUR BYE - PASS ROAD, ERUMAPALAYAM VILLAGE, SALEM TK, SALEM DT - 636 015.** Building and premises on the day of **08.07.2025** and certify that

: The accommodation provided for each of the several classes is sufficient for the maximum number of students studying therein and is properly ventilated and lighted;

: The building is maintained in substantial repair;

: The building is neat and clean;

: The toilet arrangements are adequate and satisfactory;

: The supply of drinking water is wholesome and

: That in all other necessary aspects the sanitation is satisfactory;

: That if found source of mosquito breeding in the campus,

this certificate will be automatically stands cancelled.

: The certificate is issued with the condition enclosed.

This certificate is valid **up to 07.07.2026** only.


TECHNICAL PERSONAL ASSISTANT
Office of the DHO,
SALEM - 636 001.




District Health Officer
Salem.

Signature:
Designation:


BLOCK HEALTH SUPERVISOR
GOVT UP GRADE PRIMARY HEALTH CENTRE
KANNANKURICHI
SALEM BLOCK - SALEM DIST. - 636 008

CERTIFICATE IS ISSUED SUBJECT TO THE FOLLOWING CONDITIONS:

- 1) The Garbage generated within the premises should be collected and disposed off properly by appointing required sanitary staff.
- 2) On any account, the Garbage should not be burnt.
- 3) The employees should be educated to prevent the usage of plastics in the premises and no one should bring plastic carry bags, use and throw Tumblers to the premises.
- 4) To ensure that no mosquitogenic environment in the campus under section 83 of TNPH Act, 1939.
- 5) N.O.C. (or) License for Building to be obtained under TNPH Act 1939 and Buildings Act 1965.
- 6) Fire Precautionary measures, and First Aid box, should be provided in the campus.
- 7) Sign Board regarding 'No Smoking Zone', 'Here Smoking and Spitting is an offence' should be exhibited in front of the premise.
- 8) This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of sanitation, improper maintenance of the building as well as toilets in the premises.
- 9) That if any of all above conditions are not satisfied the Certificate given will be automatically cancelled.
- 10) This certificate should be **renewed every year**.

**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY**

No.397,ANBU NAGAR GORIMEDU,SALEM - 636 008.

Phone: 0427 - 2405687

E-mail:twadboardsalemlab@gmail.com



TC - 14195

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 61894	Report Issue Date :	18.09.2025	Page No : 01 of 01
Invoice Details:	7667/Dt.16.09.2025 Amt.Rs.1652 /-	ULR No	TC141952500000937F	

Client Name & Address	:	THE PRINCIPAL,CLUNY VIDYA NIKETHAN
Contact No / Email.ID	:	(SENIOR SECONDARY SCHOOL)2/636,Attur Bypass Road, Erumapalayam,Salem- 636 015
Sample Name	:	Water
Sample Number	:	61894.
Sample Description	:	R.O. Water
Sample Submitted by	:	Ms.Mary Puspam
Location & Date	:	CLUNY VIDYA NIKETHAN (SENIOR SECONDARY SCHOOL)2/636,Attur Bypass Road, Erumapalayam,Salem- 636 015& 16.09.2025
Quantity of sample Received	:	2 Litre
Sample Container	:	Jerry Cane
Sample Condition on Receipt	:	Good
Sample Received On	:	16.09.2025
Test Commenced on	:	16.09.2025
Test Completed on	:	17.09.2025
Environmental Condition	:	23.0°C – 27.0°C

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	-	IS 3025 Part 11-2022	6.89	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009(RA 2019)	28	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-2023	32	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-(RA 2019)	12.0	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025(Part 24/Sec 1):2022 (Turbidity Method)	5.0	200	400
6	Nitrate as NO ₃	mg/L	APHA 24rd Edition – 4500 –NO ₃ B:2023	2.0	45	45
7	Fluoride as F	mg/L	APHA 24rd Edition – 4500 –F- D:2023	0.20	1.0	1.5

Remark: The tested sample conformed to IS: 10500:2012 (RA: 2019) Drinking water specification Acceptable Limit with respect to above tested parameters.

.....End of the report.....

[Signature] 18/9/25
Reviewed and Authorised by Signatory
S.C.Prakasham,
Junior Water Analyst.

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TEST REPORT

Sample Receipt No/Date :	61894-61895/Dt.16.09.2025
Invoice Details :	7667/Dt.16.09.2025
Customer Name and Address :	THE PRINCIPAL, CLUNY VIDYA NIKETHAN (SENIOR SECONDARY SCHOOL) 2/636, Attur Bypass Road, Erumapalayam, Salem- 636 015
Test Commenced on :	16.09.2025
Test Completed on :	17.09.2025
Test Report Date :	18.09.2025

SAMPLE DETAILS FURNISHED BY CUSTOMER

Source :	R.O WATER .
Location :	CLUNY VIDYA NIKETHAN (SENIOR SECONDARY SCHOOL) 2/636, Attur Bypass Road, Erumapalayam, Salem- 636 015
Sample drawn by/Date :	Customer/Dt.16.09.2025
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
Appearance, Colour, Odour :	Clear/Colourless/Agreeable

The test result of sample received is as follows.

S.No	I. Physical Examination	Method of Testing	Unit	Sample No. 61894 Result	Specification as per IS 10500 : 2012 Permissible Limit
8	Turbidity	APHA 24rd Edition 2023 - 2130 B	NTU	0.00	5
9	Total Dissolved Solids	APHA 24rd Edition 2023 - 2540 C	mg/L	75	2000
10	Electrical Conductivity	APHA 24rd Edition 2023 - 2510 B	μS/cm	107	-
	II. Chemical Examination				
11	Ph. Alkalinity as CaCO ₃	IS 3025-Part 23-1983	mg/L	0	-
12	Calcium as Ca	APHA 24rd Edition 2023 - 3500 Ca B	mg/L	8	200
13	Magnesium as Mg	APHA 24rd Edition 2023 - 3500 Mg B	mg/L	2	100
14	Sodium as Na	APHA 24rd Edition 2023 - 3500 Na B	mg/L	-	-
15	Potassium as K	APHA 24rd Edition 2023 - 3500 K B	mg/L	-	-
16	Iron as Fe	APHA 24rd Edition 2023 - 3500 Fe B	mg/L	0.00	1
17	Manganese as Mn	APHA 24rd Edition 2023 - 3500 Mn B	mg/L	0.00	0.3
18	Free Ammonia as NH ₃	APHA 17th Edition-1989- 4500 NH ₃ C	mg/L	0.00	0.5
19	Nitrite as NO ₂	APHA 24rd Edition 2023- 4500-NO ₃ B	mg/L	0.00	-
20	Phosphate as PO ₄	APHA 24rd Edition 2023 - 4500 P- D	mg/L	0.00	-
21	Free residual chlorine	BIS 10500:2012	mg/L	0.00	-
	III. Bacteriological Examination			61895	
22	Feecal Coliform per 100 ml	IS/APHA	CFU	0	0

Remarks: The given water sample is Physically, Chemically Potable and Bacteriologically not Contaminated.

.End of the report.....

Reviewed and Authorised by Signatory
S.C.Prakasham,
Junior Water Analyst.

Note:

- The test results relate only to the tested sample.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.

